

## ABAD ELECTRIC SUPPLY CO: L

**2** 041-9220397

cedev fesco@yahoo.com

Office of the. Chief Engineer (Development), PMU FESCO Faisalabad

Director (MIS

Director (AM) Deputy Preciou

5 81

Deputy

Deputy !

Deput Assista

wheret Admn

Account-Sub Engine

## EVALUATION REPORT (As per Rule 35 of Public Procurement Rules, 2004)

Name of Procuring Agency

Faisalabad Electric Supply Company (FESCO)

Method of Procurement

Single Stage Single Envelope

Title of Procurement

132KV Non Ceramic Polymer Insulators (Composite) 100-KN as per WAPDA/NTDC Specification TLMS-8A:2017 (amended to date) Minimum Leakage Distance 5616 (mm) & Maximum Permissible Section Length 1898 (mm) (LOT-1/(GSC), LOT-II/(Deposit Work) & LOT-III/(GSO)

Tender Inquiry No 4

NCB-590/FESCO/PMU/GSC&GSO&DW/20Dir24or (CC&B)

PPRA Ref. No. (TSE)

TS530807E dated 23.01.2024

Date & Time of Bidding Closing

11:00 A.M. 06.02.2024

Date & Time of Bidding Opening

12:30 P.M. 06.02.2024

8 No. of Bids Received 03 No.

As per Bidding Document

10

Details of Bids (s) Evaluation

Criteria for Bid Evaluation

As under:

	- Detail	13 Of Did3 (3) DV		r and	PAWINHIL	
	Name of Bidder	Ma Technical (If applicable)	Financial (If applicable)	Evaluated Cost (Million Rs.)	Rule/Regulation/SBD/Policy/Basis for Rejection/Acceptance as per Rule 35 of PP Rules, 2004	
	Junaid (Pvt) Ltd			164.430 (LOT-I) 99.486 (LOT-II)	The bid declared Commercially & Technically Responsive.	·
	Associated Commercial Agencies (Pvt) Ltd			130.318 (LOT-I) 61.747 (LOT-II) 34.342 (LOT-III)	The bid declared Commercially & Technically Responsive.	
	M.N. Enterprises			158.095 (LOT-I) 74.909 (LOT-II) 41.662 (LOT-III)	<ul> <li>i) The bid declared Commercially Responsive.</li> <li>ii) The bid declared Technically Non-Responsive due to:</li> <li>The bidder did not submit an undertaking to perform fresh type test as per Revised NTDC Type Test Policy and not in line with Clause-7.3 (Type Test Report), Section-Ill, Evaluation &amp; Qualification Criteria of bidding documents</li> </ul>	

Lowest Evaluated Bidder:

134 S.C. Rel (Set Date 2013) 141 orders Frank ation Report Profession do

M/s Associated Commercial Agencies (Private) Limited, Lahore

Building, Building,

11. Any other additional/supporting information, the procuring agency may like to share

Endst. No. 7545-46 /CE(Dev)PMU FESCO

Dated 14-5 24

Forwarded to the Deputy Director, Public Procurement Regulatory Authority. 1st Floor FBC Building, Near State Bank, Sector G-5/2, Islamabad for uploading at PPRA Website.

Chief Engineer (Development)

CC:-

Director General (IT) FESCO Faisalabad with the request to upload on FESCO website please

2. Master File.